

Dayan Refrigeration Supplies Ltd
26 Ha-Sadna
5881524 HOLON
ISRAEL

Certificate of Analysis

Date
15.05.2024
Purchase order item/date
POD00419 / 05.03.2024
Delivery item/date
88292279 900002 / 20.06.2024
Order item/date
2707439 000010 / 25.03.2024
Customer number
1259728

Material Code / Description
10639906 / Genetron AZ-50 R507A 10kg Jug GB EN CN

Batch 2224051005 / Quantity 800 EA

Inspection lot 529177 from 14.05.2024

Characteristic	Value	Lower Limit	Upper Limit
Acidity (as HCL), ppm	< 1,00	-	1,00
Assay %(w/w)	99,97	99,50	-
Chloride ppm(w/w)	< 1,00	-	1,00
Genetron 125, % (w/w)	50,37	49,50	51,50
Genetron143a,%(w/w)	49,63	48,50	50,50
Moisture ppm	6,00	-	10,00
Non-condensable gases %(v/v)	0,73	-	1,50
Non-volatile residue ppm(w/w)	7,00	-	100,00
Particulates and Solids	Colorless, clean	-	-

This is electronically printed from SAP system and no signature is required.